

Tabelle – Konzentration von Frostschutz und Korrosionsschutzmittel, Liter

Gefrierpunkt (°C)	-21	-24	-30	-38	-50	Volumen des Kühlsystems (Liter)
Ethylenglykol (Volumen-%)	35	40	45	50	60	
Ethylenglykol (Liter)	11	12	14	15	18	30
	14	16	18	20	24	40
	18	20	23	25	30	50
	21	24	27	30	36	60
	25	28	32	35	42	70
	28	32	36	40	48	80
	32	36	41	45	54	90
	35	40	45	50	60	100
	39	44	50	55	66	110
	42	48	54	60	72	120
	46	52	59	65	78	130
	49	56	63	70	84	140
	53	60	68	75	90	150
	56	64	72	80	96	160
	60	68	77	85	102	170
	63	72	81	90	108	180
67	76	86	95	114	190	
70	80	90	100	120	200	